



Chesapeake Ranch Water Company
Annual Water Quality Report
Calendar Year 2015

Annual Drinking Water Quality Report

CHESAPEAKE RANCH ESTATES

MD0040004

Annual Water Quality Report is for the period of January 1 to December 31, 2015.

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of drinking water used by CHESAPEAKE RANCH WATER COMPANY USERS is ground water.

For more information regarding this report contact:

Name: **George Hanson**

Phone: **410-326-4122**

The Board of Directors of Chesapeake Ranch Water Company meet at 7:00 PM on the 3rd Thursday each month.

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien.

Source of Drinking Water:

The Source of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick-up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

SOURCE WATER INFORMATION:

Source Water Name	Type of Water	Report Status	Location
BONANZA TRAIL WELL 3A CA880667	GW	—	NEAR 3 MI W OF LUSBY APPROX. 75 FT E OF BONANZA TRAIL
CLUBHOUSE DR WELL 1R CA940409	GW	Y	LUSBY APPROX. 50 FT E OF BUENA VISTA ROAD
GUNSMOKE TRAIL WELL 4 CA883340	GW	Y	NEAR 5 SE OF LUSBY APPROX. 600 FT N OF GUNSMOKE TRAIL
THUNDERBIRD DR WELL 2A CA811754	GW	Y	NEAR 3 MI SE OF LUSBY APPROX. 60 FT E OF THUNDERBIRD TRAIL

Water Quality Test Results:

Definitions: The following table contains scientific terms and measures, some of which may require explanation.

Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allows for a margin of safety.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
ppm:	Milligrams per liter or parts per million – or one ounce in 7,350 gallons of water.
ppb:	Micrograms per liter or parts per billion – or one ounce in 7,350 gallons of water.
na:	Not applicable

2015 Regulated Contaminants Detected

Lead and Copper:

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90 th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	12/31/2014	1.3	1.3	0.063		ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Chlorine	Monthly	0.8	0 – 0.8	MRDLG = 4	MRDL = 4	ppm	N	Water additive used to control microbes.
Haloacetic Acids (HAAs)	8/21/15	2	2 – 2	No goal for the total	60	ppb	N	By-product of drinking water disinfection

Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future.

Total Trihalomethanes (TTHM)	8/21/15	9	8.7 – 8.7	No goal for the total	80	ppb	N	By-product of drinking water disinfection
------------------------------	---------	---	-----------	-----------------------	----	-----	---	---

Not all sample results may have been used for calculating the Highest Level Detected because some results may be part of an evaluation to determine where compliance sampling should occur in the future

Regulated Contaminants Continued:

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic – While your drinking water meets EPA standards for arsenic, it does contain low levels of arsenic. EPAs standard balances the current understanding of arsenics possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of a low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems	Quarterly	7	4 – 8.4	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Fluoride	12/02/2014	0.4	0.4 – 0.4	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong health; discharge from fertilizer and aluminum factories.
Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Beta/photon emitters	Nov 16, 2011	4.6	4.6 – 4.6	0	4	mrem/yr.	N	Decay of natural and man-made deposits.

If you have any questions regarding this Water Quality Report you may contact the following:

George Hanson
General Manager
Chesapeake Ranch Water Company
P.O. Box 476
11560 H.G. Truman Road
Lusby, Md 20657
Office Phone: 410-326-4122
Fax: 410-326-6743
Email: gm-crwc@comcast.net